



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2023/NDZ/419

Dated: 19/06/2023

**FIRE SAFETY CERTIFICATE**

Certified that Little Star Public School running at ground and two floors building comprised of ground, first and second floor at New Chauhanpur, Karawal Nagar Rd, Delhi-94, owned/occupied by Little Star Public School was issued FSC vide letter No. F6/DFS/MS/School/2018/956 dated 08/05/2018. The premises was re-inspected by the officer concerned of this department on dated 29/05/2022 in the presence of Mr. R.N. Sharma and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. 262-362 dated-17/01/2005 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 19/06/2023 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 19/06/2023 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

To:-

1. The Principal  
Little Star Public School at New Chauhanpur, Karawal Nagar Rd, Delhi-110094
2. The Dy. Director of Education,  
B-Block, Yamuna Vihar, Delhi-110053

**Conditions for the validity of Fire Safety Certificate**

1. Fire Safety Certificate is valid for ground and first floor only. Applicant has submitted an undertaking dated 25/05/2023 that he will not use second floor for school purpose falling which this FSC should be treated null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry